



Diámetro exterior (In)		Clase.				Aprobación FM
		200		150		
Nominal.	Real.	Espesor mínimo de pared.	Diámetro interior.	Espesor mínimo de pared.	Diámetro interior.	
4	4.500	0.409	3.633	0.333	3.793	✓
6	6.625	0.602	5.348	0.491	5.585	✓
8	8.625	0.784	6.963	0.639	7.271	✓
10	10.750	0.977	8.678	0.796	9.062	✓
12	12.750	1.159	10.293	0.944	10.748	✓
14	14.000	1.273	11.302	1.037	11.801	✓

\*\*\*Para otros diámetros y RD's consultar a policonductos.



Las tuberías para redes contra incendio se fabrican con franjas rojas

Diam.	Presentacion.
4, 6, 8, 10, 12, 14	Tramos 12ML
4, 6, 8, 10, 12, 14	Tramos 6ML